

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7120-1527:100 Page 1 of 1

**CATEGORY:** Annunciators

**LISTEE:** National Time & Signal Corporation, 28045 Oakland Oaks Court, Wixom, MI 48393-3342  
Contact: Leo Mullins (248) 380-6264 \*Fax (248) 380-6268

**DESIGN:** Model 902-Annunciator. Unit comprises of an enclosure and printed circuit board. The printed circuit board employs RS-485 circuitry that allows the annunciator to communicate to the fire alarm control unit and a RS-232 output. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL label.

**APPROVAL:** Listed as an annunciator for use with separately listed compatible fire alarm control units.

\*Rev. 08-20-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**